

# NOTICE TO THE PUBLIC

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Aqua Pennsylvania Midway (PWSID# PA2400104)

### BOIL WATER NOTICE LIFTED

ESTE INFORME CONTIENE INFORMACIÓN MUY IMPORTANTE SOBRE SU AGUA POTABLE.

TRADÚZCALO O HABLE CON ALGUIEN QUE LO ENTIENDA BIEN

**The Boil Water Notice issued on Friday, July 13, 2018 has been lifted effective today, Sunday, July 15, 2018, for the Midway Water System.**

**What happened? What is being done? When will the problem be corrected?**

Due to a failure of the disinfection system, chlorine disinfection dropped below the state- required minimum level. The disinfection system issue was corrected. Two sets of samples were collected from the distribution system on Friday, July 13 and Saturday, July 14 and tested for total coliform bacteria. Results from both sets of samples were absent of total coliform bacteria on Sunday, July 15, 2018.

**It is no longer necessary to use boiled water or bottled water for drinking, making ice, brushing teeth, washing dishes and food preparation.**

Aqua is committed to providing quality water and service to its customers. We apologize for the inconvenience and thank you for your patience. Although this matter has been resolved, if you have any questions or concerns, please contact Aqua's Customer Service at 877.987.2782.

***Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.***

For more information, please contact:

<b>Responsible Person</b> Dave Hoogstad, Field Supervisor	<b>System Name</b> Midway	<b>Address (Street)</b> 1 Aqua Way
<b>Phone Number</b> 877.987.2782	<b>System PWSID#</b> PA2400104	<b>Address (City, State, Zip)</b> White Haven, PA 18661

**Date Notice Distributed: July 15, 2018**

**Date Notice Lifted: July 15, 2018**